

Red-D-Arc Welderrentals

Calibration Certificate

Miller ProHeat 35

Unit Serial Number: MA050188G

Date Tested: Nov.6, 2013

Certified Calibration

Primary Standard						
	382° (F) 2.787VDC@RC9		882° (F) 6.013VDC@RC9		1382° (F) 9.239VDC@RC9	
	RC9 output DC voltage reading	ProHeat 35 display	RC9 output DC voltage reading	ProHeat 35 display	RC9 output DC voltage reading	ProHeat 35 display
TC1	2.795	383	6.019	883	9.249	1383
TC2	2.792	383	6.025	883	9.251	1382
TC3	2.789	383	6.014	883	9.245	1382
TC4	2.789	383	6.007	883	9.243	1382
TC5	2.784	382	6.015	882	9.240	1382
TC6	2.791	382	6.020	881	9.239	1381
Allowable	2.749-2.825	+/- 3° F	5.975-6.051	+/- 3° F	9.201-9.277	+/- 3° F

Instruments Used:

Fluke 714 Thermocouple Calibrator SN: 2118055

Calibration Date: Aug.9, 2013

Precision Digital Voltage Meter SN: 2142011

Calibration Date: Aug.9, 2013

Machine re-calibration due date: Nov.6, 2014

Red-D-Arc does hereby certify the above instrument was calibrated against standards maintained by Red-D-Arc and meets or exceeds all published specifications. The accuracy of these standards is directly traceable to the National Institute of Standards and Technology.

Unit passed inspection.



Technician:

David Guryan

Date: 11/6/13

Signature